



**Tender Enquiry No. ADMIN/Tender/MGPS/1/2014**  
**Corrigendum**

Page No/ Clause no/ point no	Existing sentence	To be read as
As mentioned in tender document	Last date of submission 01-05-2014, at 14:30 PM, The technical bids shall be opened on the same day at 03.00 PM at AIIMS, Raipur.	Last date of submission <b>06-05-2014</b> , at 14:30 PM, The technical bids shall be opened on the same day at 03.00 PM at AIIMS, Raipur.
Page no. 1	EMD Amount for Schedule II - <b>₹ 5,50,000/-</b>	EMD Amount for Schedule II - <b>₹ 4,50,000/-</b>
Page no. 2	EMD Amount for Schedule III - <b>₹ 1,00,000/-</b>	EMD Amount for Schedule III - <b>₹ 2,00,000/-</b>
Page no 53, Point no.1	Wherever specifications are not mentioned, the following specification – USFDA / European CE / HTM 2022 / HTM 02-01 / C11 / NFPA 99 will apply;	Wherever specifications are not mentioned, the following specification – USFDA / European CE / HTM 2022 / HTM 02-01 / C11 / NFPA 99 / EN ISO-7396-I will apply. <b>The MGPS shall be installed as per the layout plan available with AIIMS administration; minor variations as per applicable specifications will be allowed, in case of difference of opinion the AIIMS layout plan shall prevail.</b>
Page no 57, point no. 9 & page no. 59, point no. 15	Area Isolation Valves	Area Isolation Valves <b>(should be lockable in both 'off' and 'on' position)</b>
Page no 64,	Fittings shall be degreased suitable for oxygen use and supplied sealed in protective polythene bags. Copper to copper joints shall be made on site using a silver-copper-phosphorous brazing alloy to BS 1845 using an oxygen free nitrogen inert gas shield and no flux. Copper to brass or gunmetal joints shall not be made on site. Except for mechanical joints used for components, all metallic pipeline joints shall be brazed or welded. Medical gas pipeline shall be bonded to an earth terminal as near as possible to the point at which the pipeline enters the building.	Fittings shall be degreased suitable for oxygen use and supplied sealed in protective polythene bags. Copper to copper joints shall be made on site using a silver-copper-phosphorous brazing alloy to BS 1845 using an oxygen free nitrogen inert gas shield and no flux. Copper to brass or gunmetal joints shall not be made on site. Except for mechanical joints used for components, all metallic pipeline joints shall be brazed or welded. <b>The pipeline should be purged by an inert gas (N<sub>2</sub>) and the same shall be procured by the supplier.</b> Medical gas pipeline shall be bonded to an earth terminal as near as possible to the point at which the pipeline enters the building.

Administrative Officer  
AIIMS, Raipur