



अखिल भारतीय आयुर्विज्ञान संस्थान, रायपुर (छत्तीसगढ़)
All India Institute of Medical Sciences, Raipur (Chhattisgarh)
Tatibandh, GE Road,
Raipur-492099 (CG)
www.aiimsraipur.edu.in
Ph.No.0771-2572930, e-mail: aiimsrprprojectcell@gmail.com

No. 54(8017) SE-/AIIMS/ MAINT/RPR/2016/ २१५३.

Dt. 06/09/2016

CORRIGENDUM-02

N.I.T. NO. 02/SE/AIIMS/2016-17 Dt: 17-08-2016


NAME OF WORK: - "Annual Repair and Maintenance of Civil/Horticulture/Electrical/ plumbing of Hospital Buildings, Medical College Building, Nursing College, Ayush PMR Building, Trauma Building, Service Buildings & Hostels at All India Institute of Medical Sciences, (AIIMS) Raipur".

Page No/ Clause No/	Existing sentence	To be read as
As mentioned in tender document Page no. 03	Time & Date of submission of Tender Upto 3:00 PM on 31-08-2016	Time & Date of submission of Tender Upto 3:00 PM on 13-09-2016
As mentioned in tender document Page no. 03	Time & Date for Opening of Technical & Eligible Credential 3:30 PM on 31-08-2016 (As per original NIT) 3:30 PM on 07-09-2016 (As per Corrigendum Dt:30-08-16)	Time & Date for Opening of Technical & Eligible Credential 3:30 PM on 13-09-2016
As mentioned in tender document Page no. 121	Sl.No-40	Sl.No-41
As mentioned in tender document Page no. 122 Sl.No.49	Sl.No.49	Sl.No.49 A
As mentioned in tender document Page no. 122	Not Available	Inserted row Between 49 & 49.1 Sl.No. 49 Providing and Fixing following way prewired Vertical type TP&N MCB distribution board of steel sheet for 415 volts on surface/ recess complete with loose wire box of sheet steel, dust protected , duly powder Painted, inclusive of 200 amps tinned copper bus bar, common neutral link , earth bar, din bar for mounting MCB's terminal connectors for all incoming & outgoing circuits, duly prewired with adequate size of FRLS PVC insulated copper conductor up to the terminal connector /neutral link , earthing etc. as required (But without MCB/ RCCB/ Isolator). (Note: Prewired vertical type MCB TPDB is Normally used where 3 phase outlets are required.)

As mentioned in tender
document
Page no. 124

SI.No-64 Providing and Fixing of BOX/BATTEN type for surface mounting on wall or ceiling lighting fluorescent lamp & choke similar to Phillips **TMS 122/128E** HF or equivalent with 2x28W TL5 having PF Capacitor (>0.98 Lag) & (THD < 10%).

SI.No-64 Providing and Fixing of BOX/BATTEN type for surface mounting on wall or ceiling lighting fluorescent lamp & choke similar to Phillips **TMS 122/228E** HF or equivalent with 2x28W TL5 having PF Capacitor (>0.98 Lag) & (THD < 10%).


Superintending Engineer,
6/2/16
10/10/16 A
AIIMS Raipur

Copy to:-

1. O/o Director, AIIMS, Raipur. :
2. Dy. Director (Administration), AIIMS Raipur : For kind information please.
3. FA, AIIMS Raipur : For kind information please.