



अखिल भारतीय आयुर्विज्ञान संस्थान, रायपुर (छत्तीसगढ़)
All India Institute of Medical Sciences, Raipur (Chhattisgarh)
Tatibandh, GE Road,
Raipur-492 099 (CG)
www.aiimsraipur.edu.in

Tender Enquiry No. ADMIN/Tender/MGPS/1/2013
Addendum to Corrigendum issued on 01.10.2013

The table describing BOQ for trauma building

Point no. 2. BOQ for Trauma building	Existing sentence	To be read as
Sub point no. 10	Duplex Medical Air Delivery system rated capacity 57 CFM approx. 1000 liter reservoir and Air Dryer, Air Filters and Reducing stations along with all accessories	Duplex Medical Air Delivery system rated capacity 57 CFM approx. 1000 liter reservoir and Air Dryer, Air Filters and Reducing stations along with all accessories. The medical Air delivery system should have two-stage (2-stage) air filtration.

Administrative Officer
AIIMS, Raipur